



V-SCAN CERTIFICATE AND REPORT

No: XX-XXXX

CUSTOMER:	DATE RECEIVED:
CUSTOMER PO:	SCORE JOB No:

This report provides a summary of the findings and results of the V-Scan Control Valve Diagnostic testing completed on the below valve details. All tests were completed using Score developed and owned V-Scan software.

Tag Number:	XXXXXXXX	Actuator Model:	XXXX
Type:	ANGLE VALVE	Actuator Size:	XXXX
Size/Rating:	8"/150# X 6"/150#	Actuator Fail mode:	Open / Close / Stay Put
Manufacturer:	XXXXXXXX	Positioner Model:	XXXX
Type/Model No:	XXXX	Signal Range	4-20 mA
Serial No:	XXXX		

ACTUATOR PERFORMANCE: {Identify hysteresis, supply pressure, linearity, Total travel, min. & max. signal travel, Bench set, Seat load & Spring rate}
Supply pressure was found been sizing at 56.82 PSI. This slightly lower than stated in manufacturer schematic drawing which is 4 Bar.

DYNAMIC SIGNATURE: {Identify any anomalies during valve travel in from 2mA signal to 22 mA}
Valve was found have bad dynamic signature during travel with decreasing signal especially from 12mA to 4mA signal.


FRICITION: {Measure and Identify the value of stem & packing friction of the valve from 10% to 90% of travel}
The friction value was found high when valve travel in between 10% to 20%.

VALVE SIGNATURE: {Identify differential pressure during valve travel}
Differential pressure with decreasing signal was found badly fluctuated during travel from 40% to 0%.

STEP TEST: {Measure percentage deviation of percentage of valve travel against percentage of current signal}
No issue were noted. Valve was found travel at desired value with total percentage of deviation is below than 5%.

TRIP TEST: {Measure time of valve travel from 0 to 100% and vice-versa}
No Issue were noted during the trip test. Calculated Rising time (Time to Open) is 0.77 second and falling time (time to Close) is 1.02 second. Both rising and falling time was below than 5 second as per stated in the manufacturer datasheet.

NOTES: {Any additional issue noted during the testing}
No issue were noted.





CONTROL VALVE

V-SCAN SIGNATURE
CERTIFICATE



Score Asia Sdn Bhd
Intelligent Valve and Gas Turbine Solutions

Score Asia Sdn Bhd
Lot A-C Level 9
Tower 2 Etiqa Twins
11 Jalan Pinang
50450 Kuala Lumpur
Tel: +603 2161 6641
Fax: +603 2162 6640

Valve Identification		8-5-2015
Tag Number		
Manufacturer Serial		
Score URN		
Client		
Plant		
Location		

Valve Configuration		
Valve Manufacturer	XXXX	
Valve Configuration	LINEAR	
Valve Type	ANGLE	
Valve Model	XXXX	
Pressure Class	150	
Valve Size	8 X 6 X 10	in
Stem Packaging	GRAPHOIL	
Flow Direction	OVER	
Expected Packing Friction	207.80	lbf

Valve Trim		
Seat Diameter	6	
Expected Seat Load	8192.50	lbf
Flow Characteristics	LINEAR	
Stem Diameter	1.6	in
Seal Material	METALLIC	
Seat Leak Class	CLASS V	
Pressure Balance	BALANCE	
Trim Design	BONNET GUIDED PLUG	

Actuator		
Actuator Manufacturer	XXXX	
Actuator Style	DOUBLE ACTING WITHOUT SPRING PISTON	
Actuator Model	XXXX	
Actuator Size	XXXX	mm
Top Area	113	in ²
Bottom Area	85	in ²
Nominal Stroke	2.3622	in
Fail Mode	CLOSE, AIR TO OPEN	
Nominal Spring Start Point	-	psig
Nominal Spring End Point	-	psig
Spring Rate	-	lbf/in




Valve Positioner


Positioner	XXXX	
Signal Range	4-20 MA	
Positioner Style	SMART HART	
Positioner Model	XXXX	
Extras		

Performance	As Found	Acceptable	
Avg HD	2.46	≤ 5.00	% fs
Supply Pressure	56.82	58.00 – 137.75	PSI
Linearity	3.66	≤ 5.00	% fs
Measured Total Travel	2.40	2.45	in
Signal Minimum Travel	5.12	4.00 – 5.50	mA
Signal Maximum Travel	20.32	19.50 - 20.50	mA
Measured Spring Start Point	0.00	-	psig
Measured Spring End Point	0.00	-	psig
Seat Load as tested	6240.70	≤ 8192.50	lbf
Spring Rate	0.00	-	lbf/in

Actuator Performance




Dynamic Signature






<i>Performance</i>	<i>As Found</i>	<i>Acceptable</i>	
Avg Friction	185.92	284	lbf
Max Friction	490.88	284	lbf
Min Friction	0.61	284	lbf

Friction



Valve Signature






Step Test

Valve Identification		8-5-2015	
Tag Number	XXXXXX	Actuator Model	XXXX
Manufacturer Serial	XXXXXX	Air Action	AIR TO OPEN
Company	XXXX	Fail Mode	CLOSE
Valve Manufacturer	XXXX	Positioner	XXXX
Valve Configuration	LINEAR	Cam Profile	BALANCE
Valve Type	ANGLE	Signal Source	SMART HART
Valve Model	XXXX	Signal Range	4-20 MA
Valve Size	8" X 6" X 10"	Minimum Air Pressure	20 PSI
Actuator Manufacturer	XXXX	Extras	
Actuator Style	DOUBLE ACTING WITHOUT SPRING PISTON		

Input	Output	%Dev
-25%	0.00%	0.00%
0%	0.00%	0.00%
25%	24.05%	0.95%
50%	50.04%	0.04%
75%	75.66%	0.66%
100%	101.29%	1.29%
125%	101.61%	1.61%
100%	101.06%	1.06%
75%	75.34%	0.34%
50%	49.79%	0.21%
25%	23.76%	1.24%
0%	0.00%	0.00%

Large Amplitude Step Response Test





Trip Test

Valve Identification		8-5-2015	
Tag Number	XXXXXX	Actuator Model	XXXX
Manufacturer Serial	XXXXXX	Air Action	AIR TO OPEN
Company	XXXX	Fail Mode	CLOSE
Valve Manufacturer	XXXX	Positioner	XXXX
Valve Configuration	LINEAR	Cam Profile	BALANCE
Valve Type	ANGLE	Signal Source	SMART HART
Valve Model	XXXX	Signal Range	4-20 MA
Valve Size	8" X 6" X 10"	Minimum Air Pressure	58 PSI
Actuator Manufacturer	XXXX	Extras	
Actuator Style	DOUBLE ACTING WITHOUT SPRING PISTON		

Item	Value	Unit
Rising Time	0.77	Second
Falling Time	1.02	Second

TRIP TEST GRAPH

